



RURAL POWER COMPANY LIMITED

Correction of Amendments and Clarifications

FOR

**ENGINEERING, DESIGN, MANUFACTURING, INSPECTION, SUPPLY,
TRANSPORTATION, CONSTRUCTION, ERECTION, INSTALLATION,
TESTING AND COMMISSIONING OF MYMENSINGH 360 MW DUAL
FUEL(GAS/HSD) COMBINED CYCLE POWER PLANT PROJECT ON
TURNKEY BASIS.**

REF: PUR: 020(FW/MYMENSINGH 360 MW/OTM)/2017-18;DATE:31.01.2018

Sl no.	Volume/ Clause	Page No	As per Original Tender Document	Previously Released Clarification	Corrected Amendment & Clarification
419	Vol. 2 of 2 (Part A)	24 & 368	In addition to the above Spares & consumables during Warranty period, the Tenderer shall, also submit separate lists (from GT manufacturer) of spare & consumables required for 02 CI and 01 HGPI (If proposed GT manufacturer is GE), 01 CI and 01 TI (If proposed GT manufacturer is MHI), 02 Type A inspection and 01 Type B inspection (If proposed GT manufacturer is Alstom), 03 MI (If proposed GT manufacturer is Siemens), 03 MI (If proposed GT manufacturer is Ansaldo). Contractor shall supply these spare & consumables under this contract within their quoted price. These spare & consumables will be used only at the time of scheduled inspections of GT during warranty period and after warranty period. These spares and consumables cannot be used against warranty claim for installed GT components.	Please refer to the section 22.1 and 22.2 of tender vol 2 of 2 (part A)	In addition of the above warranty period Spares & Consumables, bidder shall supply spares and consumables for schedule inspection of GT 24000 operating hours/equivalent operating hours. Bidder shall have to submit GT Manufacturer guide line for Schedule inspection interval, detail list of the spare for each type of schedule inspection from GT manufacturer along with GT manufacturer along with GT manufacturer covering letter. Otherwise bidder may not consider for further evaluation. These spare & consumables will be used only at the time of scheduled inspections of GT during warranty period and after warranty period. These spare & consumables cannot be used against warranty claim or as wear and tear spares for installed GT components.
544	Vol 1	23	average annual construction turnover i.e total certified payments received for contracts in progress or completed under public sector for a period as stated under ITT Sub Clause 15.1(a), substantiated by Statement(s) of Receipts, from any scheduled Bank of Bangladesh, issued not earlier than twenty-eight (28) days prior to the day of the original deadline for submission of Tenders;		average annual construction turnover i.e total certified payments received for contracts in progress or completed under public sector for a period as stated under ITT Sub Clause 15.1(a), substantiated by Statement(s) of Receipts, from any scheduled Bank of Tenderers, issued not earlier than twenty-eight (28) days prior to the day of the original deadline for submission of Tenders;
545	Vol 1	42	Form Fin-4: Financial Resources Requirement for the Subject Contract (Employee to specify) US\$ 45 million		Form Fin-4: Financial Resources Requirement for the Subject Contract (Employee to specify) US\$

Dahn

